

UC-TM 8 BN - Marker for terminal blocks



0804191

<https://www.phoenixcontact.com/us/products/0804191>

Please be informed that the data shown in this PDF document is generated from our online catalog. Please find the complete data in the user documentation. Our general terms of use for downloads are valid.

Marker for terminal blocks, can be labeled with: BLUEMARK ID COLOR, BLUEMARK ID, BLUEMARK CLED, PLOTMARK, CMS-P1-PLOTTER, mounting type: snap in, for terminal block width: 8 mm



Commercial data

Item number	0804191
Packing unit	10 pc
Minimum order quantity	10 pc
Note	Made to order (non-returnable)
Sales key	BG06
Product key	BG2117
GTIN	4055626232782
Weight per piece (including packing)	13.11 g
Weight per piece (excluding packing)	13.11 g
Customs tariff number	39269097
Country of origin	PL

UC-TM 8 BN - Marker for terminal blocks



0804191

<https://www.phoenixcontact.com/us/products/0804191>

Technical data

Product properties

Product type	Terminal marker
Pitch	8 mm

Marking

Slot type	high
-----------	------

Dimensions

Width	7.60 mm
Height	10.50 mm
Depth	4.30 mm
Pitch	8 mm

Material specifications

RoHS compliant	yes
Color	brown
Flammability rating according to UL 94	V2
Fire protection for rail vehicles (DIN EN 45545-2) R22	HL 1 - HL 2
Fire protection for rail vehicles (DIN EN 45545-2) R23	HL 1 - HL 2
Fire protection for rail vehicles (DIN EN 45545-2) R24	HL 1 - HL 2

Environmental and real-life conditions

Test for substances that would hinder coating with paint or varnish

Testing for paint wetting impairment substances (LABS-conformity)	VW PV 3.10.7:2005-02
Result	Test passed

UV resistance

Specification	ISO 4892-2:2013-03 (following)
Result	Test passed
Test duration	96 h

Wipe resistance of inscriptions

Specification	DIN EN 61010-1 (VDE 0411-1):2011-07 DIN EN 62208 (VDE 0660-511):2012-06 (in parts)
Isopropanol (99%) [67-63-0]	Test passed
n-Hexane [CAS No. 110-54-3]	Test passed
Water + Petroleum ether [CAS No. 64742-82-1]	Test passed

Testing in a condensation changing climate in the presence of sulfur dioxide

Specification	DIN 50018:2013-05
Result	Test passed

UC-TM 8 BN - Marker for terminal blocks



0804191

<https://www.phoenixcontact.com/us/products/0804191>

Climate level	AHT 1.0 S
Cycles	2

Salt spray test

Specification	DIN EN 60068-2-11:2000-02
Result	Test passed

Mounting

Mounting type	snap in
---------------	---------

UC-TM 8 BN - Marker for terminal blocks



0804191

<https://www.phoenixcontact.com/us/products/0804191>

Classifications

UNSPSC

UNSPSC 21.0	39131500
-------------	----------

UC-TM 8 BN - Marker for terminal blocks



0804191

<https://www.phoenixcontact.com/us/products/0804191>

Environmental product compliance

EU RoHS

Fulfills EU RoHS substance requirements	Yes, No exemptions
---	--------------------

EU REACH SVHC

REACH candidate substance (CAS No.)	No substance above 0.1 wt%
-------------------------------------	----------------------------

Phoenix Contact 2026 © - all rights reserved

<https://www.phoenixcontact.com>

Phoenix Contact USA
586 Fulling Mill Road
Middletown, PA 17057, United States
(+717) 944-1300
info@phoenixcon.com